



City of Cambridge

PURCHASING DEPARTMENT

795 Massachusetts Ave. • Cambridge, Massachusetts 02139-3219

Amy L. Witts
Purchasing Agent

TO: All Bidders

FROM: City of Cambridge

DATE: January 23, 2017

RE: File No. 7484 – Robert W. Healy Public Safety Facility Elevator Upgrade-Addendum No.2

This addendum is comprised of:

1. Pre-bid meeting sign-in sheet (attached)
2. Questions and answers

The following questions were asked and answered:

Question: At the walk through today Peter A. Boureau the facilities manager stated he thought The door operators were going to be replaced but I don't see it listed in the bid specs.

Answer: Montgomery door closer should be included.

Question: The specs call for Main and auxiliary car operating panels but the elevator only has one car operating panel. Please advise

Answer: Just the main car operating panels should be replaced.

Question: The specs call for all new hall push buttons but the push buttons in the hall that will control all three elevators appear to be new. Please advise.

Answer: Only the 1st floor indicator light needs to be replaced.

All other details remain the same.

A handwritten signature of Amy L. Witts in cursive script, followed by a horizontal line.

Amy L. Witts
Purchasing Agent

Addendum No. 2

PRE-BID CONFERENCE SIGN IN SHEET

PROJECT: HEALY ELEVATOR UPGRADE

DATE/TIME: WEDNESDAY, JANUARY 18, 2017 AT 11:00 AM

LOCATION: RMHPSF 4ST FLOOR TRAINING ROOM

125 SIXTH STREET, CAMBRIDGE, MA

NAME: Peter H. Brennan	COMPANY: CDD	ADDRESS: 125 SIXTH ST
PHONE NO: 781-389-3647	FAX NO:	EMAIL ADDRESS: PHOB@CDD.COM
2ND PRE BID 1-23-17 1:00 PM		
NAME: Kate Wells	COMPANY: United Rentals	ADDRESS: 195 Liberty End St Plc
PHONE NO: 816-641-0058	FAX NO:	EMAIL ADDRESS: Rick@unitedrentals.com
NAME:	COMPANY:	ADDRESS:
PHONE NO:	FAX NO:	EMAIL ADDRESS:
NAME:	COMPANY:	ADDRESS:
PHONE NO:	FAX NO:	EMAIL ADDRESS: